


NEBRASKA

Good Life. Great Safety.

STATE FIRE MARSHAL AGENCY



Jim Pillen, Governor

March 25, 2025.

K&K Hubbard Mini-Mart LLC
1553 164TH ST
Jackson, Ne 68743

Facility ID: 12031
Facility Location: 319 Main St
Hubbard, Nebraska 68741

Dear Mr. Larson,

Due to failure to comply with the requirements of Title 159 Chapter 7, Chapter 5 and Chapter 13, tanks 001, 002 and 003 of your facility are hereby subject to delivery prohibition. Title 159 specifies Underground Storage Tank (UST) systems may be subject to delivery prohibition as a result of non-compliance with Leak Detection Requirements of Chapter 7. (Title 159 001.01B) Overfill Requirements Chapter 5. (Title 159 Chapter 5 001.01D) Operator Training Requirements of Chapter 13. (Title 159 Chapter 13 001.01F) Lawful orders were issued to correct the above items on April 11, 2024, May 26, 2024, August 14, 2024, September 26, 2024, and October 31, 2024, during which time none of these items have been resolved.

The following list applies to UST systems subject to delivery prohibition:

- A. No owner or operator may deposit or accept the deposit of any regulated substance into an UST system that has been designated as ineligible for fuel deliveries by the application of a red tag. TITLE 159 11-002.01
- B. No product deliverer or other person may deliver or deposit any regulated substance into an UST system that has been designated as ineligible for fuel deliveries by the application of a red tag. TITLE 159 11-002.02
- C. No person other than the State Fire Marshal shall remove a red tag from an UST system without prior approval. TITLE 159 11-003.01

MAIN / DISTRICTS A & B / BOILERS / FIRE PREVENTION / INVESTIGATIONS / PLANS
246 South 14th Street, Suite 1
Lincoln, NE 68508
(402) 471-2027

FUELS DIVISION
 FLST PIPELINE SAFETY
246 South 14th Street, Suite 1
Lincoln, NE 68508
(402) 471-9465


ELEVATOR DIVISION
1313 Farnam Street, Room 233
Omaha, NE 68102
(402) 595-3184

TRAINING DIVISION
3347 West Capital Avenue
Grand Island, NE 68803
(308) 385-6892

D. The State Fire Marshal shall verify compliance within two (2) business days of receiving a communication from the owner or operator that the corrections have been made. If the UST system is found to be eligible for delivery, the State Fire Marshal shall remove the red tag. As soon as practicable, but no more than three (3) business days after removal of the red tag, the facility shall be removed from the State Fire Marshal website list of sites ineligible for delivery. TITLE 159 11-003.02

In order to resume receiving fuel deliveries, please correct the violations as outlined on the attached order form and associated comments sheet. We look forward to resolving these items with you as quickly as possible.

Sincerely,



Larry Wiese #8742
Deputy State Fire Marshal
Fuels Division, FLST Section

MAIN OFFICE
246 South 14th Street
Lincoln, NE 68508-1804
Office (402) 471-2027

DISTRICT A OFFICE
246 South 14th Street
Lincoln, NE 68508-1804
Office (402) 471-2590

DISTRICT B/C OFFICE
438 West Market
Albion, NE 68620-1241
Office (402) 395-2164

FUELS DIVISION
 FLST Pipeline Safety
246 South 14th Street
Lincoln, NE 68508-1804
Office (402) 471-9465

TRAINING DIVISION
3347 W Capital Ave
Grand Island, NE 68801
Office (308) 385-6892

