



#

Jim Pillen, Governor

October 21, 2024

Mikael Lage
EPA Compliance Coordinator
Casey's Retail Co.
P. O. Box 3001
Ankeny, IA 50021

Facility ID: 2878
Facility Location: Casey's General Store #2722
1424 Dakota Street
South Sioux City, NE 68776

Dear Ms. Lage,

Due to failure to comply with the requirements of Title 159 Chapter 7, Chapter 5 and Chapter 13, tanks 001, 002, 003 and 004 of your facility are hereby subject to delivery prohibition. Title 159 specifies Underground Storage Tank (UST) systems may be subject to delivery prohibition as a result of non-compliance with Leak Detection Requirements of Chapter 7. (Title 159 001.01B) Overfill Requirements Chapter 5. (Title 159 Chapter 5 001.01D) Operator Training Requirements of Chapter 13. (Title 159 Chapter 13 001.01F) Lawful orders were issued to correct the above items on June 6, August 12, and September 19, 2024, during which time none of these items have been resolved.

The following list applies to UST systems subject to delivery prohibition:

- A. No owner or operator may deposit or accept the deposit of any regulated substance into an UST system that has been designated as ineligible for fuel deliveries by the application of a red tag. TITLE 159 11-002.01
- B. No product deliverer or other person may deliver or deposit any regulated substance into an UST system that has been designated as ineligible for fuel deliveries by the application of a red tag. TITLE 159 11-002.02

MAIN / DISTRICTS A & B / BOILERS / FIRE PREVENTION / INVESTIGATIONS / PLANS
246 South 14th Street, Suite 1
Lincoln, NE 68508
(402) 471-2027

FUELS DIVISION
 FLST PIPELINE SAFETY
246 South 14th Street, Suite 1
Lincoln, NE 68508
(402) 471-9465


ELEVATOR DIVISION
1313 Farnam Street, Room 233
Omaha, NE 68102
(402) 595-3184

TRAINING DIVISION
3347 West Capital Avenue
Grand Island, NE 68803
(308) 385-6892

- C. No person other than the State Fire Marshal shall remove a red tag from a UST system without prior approval. TITLE 159 11-003.01
- D. The State Fire Marshal shall verify compliance within two (2) business days of receiving a communication from the owner or operator that the corrections have been made. If the UST system is found to be eligible for delivery, the State Fire Marshal shall remove the red tag. As soon as practicable, but no more than three (3) business days after removal of the red tag, the facility shall be removed from the State Fire Marshal website list of sites ineligible for delivery. TITLE 159 11-003.02

In order to resume receiving fuel deliveries, please correct the violations as outlined on the attached order form and associated comments sheet. We look forward to resolving these items with you as quickly as possible.

Sincerely,



Larry Wiese #8742
Deputy State Fire Marshal
Fuels Division, FLST Section

