

Nebraska State Fire Marshal

Fuels Safety Division—FLST Section

UST Inspection Checklist



Facility Name: Vic's Service

Facility ID #: 4841

Date of Inspection: 01/26/2026

Jurisdiction: NE

Inspection Type	Action
<input type="checkbox"/> Initial	<input checked="" type="checkbox"/> Orders Issued
<input checked="" type="checkbox"/> Revisit	<input type="checkbox"/> Tanks Approved (List SFM ID#s): <input type="checkbox"/> Operating Permit To Follow <input checked="" type="checkbox"/> GIS: 42.750640, -98.033792 <input checked="" type="checkbox"/> Delivery Prohibited (List SFM ID#s): 05, 06



Good Life. Great Safety.

STATE FIRE MARSHAL AGENCY



Jim Pillen, Governor

January 26, 2026

VICs SERVICE LLC
PO BOX 231
Niobrara, Ne 68760

Facility ID: 4841
Facility Location: Vics Service LLC
252-20 Walnut Ave
Niobrara, Ne 68760

Dear Mr. Janak,

Due to failure to comply with the requirements of Title 159 Chapter 7, Chapter 5 and Chapter 13, tank 04 of your facility are hereby subject to delivery prohibition. Title 159 specifies Underground Storage Tank (UST) systems may be subject to delivery prohibition as a result of non-compliance with Leak Detection Requirements of Chapter 7. (Title 159 001.01B) Overfill Requirements Chapter 5. (Title 159 Chapter 5 001.01D) Operator Training Requirements of Chapter 13. (Title 159 Chapter 13 001.01F) Midwest Petroleum report dated 04/11/2025, SFM inspections initial inspection dated 03/06/2025, 1st revisit 04/30/2025, 2nd revisit 08/11/2025, 3rd revisit 08/26/2025 to today's date none of these items have been resolved.

The following list applies to UST systems subject to delivery prohibition:

- A. No owner or operator may deposit or accept the deposit of any regulated substance into an UST system that has been designated as ineligible for fuel deliveries by the application of a red tag. TITLE 159 11-002.01
- B. No product deliverer or other person may deliver or deposit any regulated substance into an UST system that has been designated as ineligible for fuel deliveries by the application of a red tag. TITLE 159 11-002.02
- C. No person other than the State Fire Marshal shall remove a red tag from an UST system without prior approval. TITLE 159 11-003.01

MAIN / DISTRICTS A & B / BOILERS / FIRE PREVENTION /
INVESTIGATIONS / PLANS
246 South 14th Street, Suite 1
Lincoln, NE 68508
(402) 471-2027

FUELS DIVISION
 FLST PIPELINE SAFETY
246 South 14th Street, Suite 1
Lincoln, NE 68508
(402) 471-9465


ELEVATOR DIVISION
1313 Farnam Street, Room 233
Omaha, NE 68102
(402) 595-3184

TRAINING DIVISION
3347 West Capital Avenue
Grand Island, NE 68803
(308) 385-6892

D. The State Fire Marshal shall verify compliance within two (2) business days of receiving a communication from the owner or operator that the corrections have been made. If the UST system is found to be eligible for delivery, the State Fire Marshal shall remove the red tag. As soon as practicable, but no more than three (3) business days after removal of the red tag, the facility shall be removed from the State Fire Marshal website list of sites ineligible for delivery. TITLE 159 11-003.02

In order to resume receiving fuel deliveries, please correct the violations as outlined on the attached order form and associated comments sheet. We look forward to resolving these items with you as quickly as possible.

Sincerely,



Larry Wiese #8742
Deputy State Fire Marshal
Fuels Division, FLST Section