

STATE OF NEBRASKA



Pete Ricketts
Governor



Jim Heine
Fire Marshal

Fire Protection of Cooking Operations

Cooking equipment shall not be required to be protected by a fire suppression system or an exhaust hood when ALL of the following requirements are met, each box is marked, and this form is signed and dated by all parties:

Portable fire extinguishers shall be provided in the vicinity of the cooking equipment in accordance with NFPA 10.

Readily visible permanent signage shall be provided at the cooking equipment stating:
"NO FRYING PERMITTED"

Food prepared in this facility shall not be sold and is therefore not considered Commercial Cooking.

OR Cooking equipment located within an educational classroom, or classroom setting (consumer science) shall not be required to be protected by a fire suppression system or an exhaust hood when ALL of the following requirements are met, each box is marked, and this form is signed and dated by all parties:

Portable fire extinguishers shall be provided in the vicinity of the cooking equipment in accordance with NFPA 10.

Cooking is supervised at all times.

A supervised fire sprinkler system protects the room where cooking is conducted.

This document applies to commercial or residential cooking equipment and includes ranges, induction appliances and portable cooking equipment such as hot plates.

By signing this document, you agree to the above conditions. Any changes to the terms agreed upon must be approved by the authority having jurisdiction.

Name of Facility Address/City

Owner/Operator Date

State Fire Marshal Representative Date

RE: National Fire Protection Association (NFPA) 96, 1.2

MAIN OFFICE
 DISTRICT A
246 South 14th Street
Lincoln, NE 68508-1804
(402) 471-2027

DISTRICT B
438 West Market
Albion, NE 68620-1241
(402) 395-2164

FUELS DIVISION
 FLST **Pipeline**
246 South 14th Street
Lincoln, NE 68508-1804
(402) 471-9465

TRAINING DIVISION
2410 North Wheeler Avenue
Suite 112
Grand Island, NE 68801-2376
(308) 385-6892