

Chapter 12 – INSPECTIONS

001. SAFETY INSPECTIONS

Periodic safety inspections shall be conducted by State Fire Marshal personnel. All tanks shall be subject to at least one inspection annually.

001.01. Inspections shall include, but not be limited to, inspection of release detection records, release detection equipment, vent pipes and dispenser systems, corrosion protection records, and applicable fire safety codes.

001.02. Findings of irregularities or insufficient record or monitoring procedures may result in an order by the State Fire Marshal to correct all such problems. State Fire Marshal personnel shall perform a follow-up inspection to insure compliance with the order. At that time, all tanks found not in compliance shall have their operating permits suspended or revoked until such time as the order is followed.

002. SPOT CHECKS

Periodic spot checks of tank monitoring systems shall be conducted by State Fire Marshal personnel.

002.01. Inspections shall cover monitoring systems and inventory control procedures.

Legal Citation: Title 159, Chapter 12
Nebraska State Fire Marshal